



## Tool/Cord Inspection

Inspector Name:		Inspection Date:	
Project:			

Enter Pass (P) Fail (F) or NA for each item below.

Tool Type & ID	Insulation Intact	Ground Prong	Double Insulated	Handles Attached	Plug or Receptacle	Cracks or Defects	Guards

**\*Any response of Fail requires a 'Red Tag' and removal from service pending repair or disposal.**

**INSPECTOR NOTE:**

Your name indicates that you have inspected the cord/tool listed above and verified the findings marked in the checklist. You also agree to follow up on tracking the repair/disposal of any cord/tool that is "red tagged" during inspection.

**INSPECTOR SIGNATURE:** \_\_\_\_\_

*Portable cord and plug connected equipment and flexible cord sets (extension cords) shall be visually inspected before use on any shift for external defects (such as loose parts, deformed and missing pins, or damage to outer jacket or insulation) and for evidence of possible internal damage (such as pinched or crushed outer jacket). Cord and plug connected equipment and flexible cord sets (extension cords) which remain connected once they are put in place and are not exposed to damage need not be visually inspected until they are relocated.*